## Claims

What is claimed is:

1. A system for detecting one or more shorted rotor turns in a field winding of an electric generator, comprising:

an electrical tap for measuring a first voltage drop $V_{f1}$ and a subsequent voltage drop $V_{f2}$ across said field winding;

an electrical shunt for measuring a first current $I_{f1}$ and a subsequent current $I_{f2}$ entering said field winding;

an impedance-measuring circuit for determining a reference inductance $L_{REF}$ based on $V_{f1}$ and $I_{f1}$ and for determining a subsequent inductance L based on $V_{f2}$ and $I_{f2}$;

a memory circuit for storing $L_{REF}$; and

a data processing system for comparing $L_{REF}$ to said subsequent inductance L to determine whether $L_{REF}$ and said subsequent inductance L differ by more than a predetermined amount and for providing an alarm to indicate the presence of said one or more shorted rotor turns when $L_{REF}$ and said subsequent inductance L differ by more than said predetermined amount.

2. The system of claim 1 wherein said impedance-measuring circuit comprises circuitry for isolating harmonic components $V_0$ and $I_0$ and an

associated harmonic frequency $\omega_0$ using Fourier analysis and for determining $L_{REF}$ and L via a formula $L = V_o / (\omega_0 * I_o)$.

3. The system of claim 1 wherein said impedance-measuring circuit comprises an inductance-measuring bridge.

4. The system of claim 1 wherein said impedance-measuring circuit is located onboard a spinning rotor of said electrical generator.

5. The system of claim 4 further including a telemetry circuit for transmitting data from said impedance-measuring circuit to a remote location.

6. A method for detecting one or more rotor turn shorts in a field winding of an electric generator, comprising the steps of:

taking a first measurement of a voltage $V_{f1}$ across said field winding;

taking a first measurement of a current $I_{f1}$ entering said field winding;

analyzing said first measurement $V_{f1}$ and $I_{f1}$ to isolate a harmonic component $V_{o1}$ of $V_{f1}$ and a harmonic component $I_{o1}$ of $I_{f1}$ and an associated harmonic frequency $\omega_{01}$;

calculating a reference inductance $L_{REF}$ based on said first measurements;

taking a subsequent measurement of a voltage $V_{f2}$ across said field winding;

taking a subsequent measurement of a current $I_{f2}$ entering said field winding;

analyzing said subsequent measurement $V_{f2}$ and $I_{f2}$ to isolate a harmonic component $V_{o2}$ of $V_{f2}$ and a harmonic component $I_{o2}$ of $I_{f2}$ and an associated harmonic frequency $\omega_{02}$;

calculating a subsequent inductance L based on said subsequent measurements;

comparing said reference inductance $L_{REF}$ to said subsequent inductance L to determine whether said reference inductance $L_{REF}$ and said subsequent inductance L differ by more than a predetermined amount; and

providing an alarm indication if said reference inductance $L_{REF}$ and said subsequent inductance L differ by more than said predetermined amount.

7. The method of claim 6 wherein said predetermined amount is a difference between $L_{REF}$ and L of about 5%.

8. The method of claim 6 wherein said harmonic component is a fundamental harmonic component.

9. The method of claim 6 further comprising the step of transmitting said alarm via telemetry to a remote location.

10 The method of claim 6 wherein said step of calculating a reference inductance $L_{REF}$ and said step of calculating a subsequent inductance L comprises using a formula $L_{REF} = V_{o1} / (\omega_{01} * I_{o1})$ and $L = V_{o2} / (\omega_{02} * I_{o2})$, respectively.

11. A method of detecting a shorted rotor turn in a field winding of an electric generator, comprising the steps of:

determining a reference inductance $L_{REF}$ for said field winding at an initial time;

determining a second inductance L for said field winding at a time subsequent to said initial time;

comparing said reference inductance $L_{REF}$ to said second inductance L to determine whether said reference inductance $L_{REF}$ and said second inductance L differ by more than a predetermined amount; and

providing an alarm if said reference inductance $L_{REF}$ and said second inductance L differ by more than said predetermined amount.

12. The method of claim 11 wherein said predetermined amount is a difference between $L_{REF}$ and L of about 5%.

13. The method of claim 11 further comprising the step of transmitting said alarm via telemetry to a remote location.

14. The method of claim 11 wherein said step of calculating a reference inductance $L_{REF}$ and said step of calculating a second inductance L includes isolating harmonic components $V_0$ and $I_0$ with a harmonic frequency $\omega_0$ and using the formula $L = V_o / (\omega_0 * I_o)$.

15. The method of claim 14 wherein said harmonic component is a fundamental harmonic component.

16. The method of claim 11 wherein said step of calculating a reference inductance $L_{REF}$ and said step of calculating a second inductance L includes obtaining an indication of $L_{REF}$ and L from an inductance measurement bridge.

17. The method of claim 11 wherein said step of determining a reference inductance $L_{REF}$ and said step of determining a second inductance L comprises taking measurements from said field winding while said electrical generator is in operation.